



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NG-4313BQ0528

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of gas supply <i>Produkte der Gasversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Düker GmbH Würzburger St. 10-16, D-97753 Karlstadt
Distributor <i>Vertreiber</i>	Düker GmbH Würzburger St. 10-16, D-97753 Karlstadt
Product Category <i>Produktart</i>	gas fittings: Shut-off valve for local gas distribution <= PN 16 (4313)
Product Description <i>Produktbezeichnung</i>	shut-off valve (soft-sealing) with stem thread on the inside and exchangeable stem sealing
Model <i>Modell</i>	2004; 3004; 4004
Test Reports <i>Prüfberichte</i>	type testing: 21-00188-AB-01-083 from 24.02.2022 (EBI)
Test Basis <i>Prüfgrundlagen</i>	DIN EN 13774 (01.05.2013)

Date of Expiry / File No. 25.11.2025 / 21-0078-GNV
Ablaufdatum / Aktenzeichen

06.04.2022 Kö A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Gas Category <i>Gasart</i>	Remarks <i>Bemerkungen</i>
fuel gases according to G 260: 03.2013	

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 40	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 50	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 65	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 80	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 100	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 125	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 150	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 200	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 250	
2004; 3004; 4004	nominal pressure rating: MOP 16 nominal diameter: DN 300	

Type Variation <i>Ausführungsvariante</i>	Explanations <i>Erläuterungen</i>
2004	connections: on both sides flanges according to DIN EN 1092-2; length: basic series 14 according to EN 558-1
3004	connections: on both sides welded ends according to DIN EN 12627; length: basic series 15 according to DIN EN 12982
4004	connections: on both sides flanges according to DIN EN 1092-2 or transition fitting (only up to DN 200, PN=10 bar), tested according to DVGW G 5600-1 for pipes d 50...d 225 made of PE 100; length: basic series 15 according to EN 558-1 (flange variation)

certified Components**zertifizierte Bauteile / Werkstoffe**

Registr. No. <i>Registrier-Nr.</i>	Component <i>Bauteil (Produktart)</i>	Model/Type <i>Modell/Typ</i>	Manufacturer <i>Hersteller</i>
NG-5113BU0424	Elastomer material for seals in gas supply mains and pipelines	51 D 55 90/51D5590	WOCO IPS GmbH
DG-5113CQ0247	Elastomer material for seals in gas supply mains and pipelines	01/AA70NBR/01/AA70NBR	LAV.EL GOMMA S.r.l.
NG-5162CO0546	Materials for greasing of gas appliance	Klübersynth V 94-751/Klübersynth V 94-751	Klüber Lubrication München SE & Co. KG

Hints of Utilization / Remarks**Verwendungshinweise / Bemerkungen**

max. operation pressure : 16 bar respectively 10 bar (variation with material transitions)
ambient temperature range: -10...+60 °C

