



CERT

DVGW type examination certificate

DVGW-Baumusterprüfzertifikat

DW-6216CS0382

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Düker GmbH Hauptstraße 39-41, D-63846 Laufach
Distributor <i>Vertreiber</i>	Düker GmbH Hauptstraße 39-41, D-63846 Laufach
Product Category <i>Produktart</i>	Valves for water supply: valves for water supply, check valves (6216)
Product Description <i>Produktbezeichnung</i>	nozzle check valve
Model <i>Modell</i>	Typ 8015
Test Reports <i>Prüfberichte</i>	Laboratory control test: from 27.06.2022 (TZW) Type testing: A0 023/17 from 19.10.2017 (TZW) UBA Guideline: Z-339870-21-Hy210 from 05.02.2021 (WHY)
Test Basis <i>Prüfgrundlagen</i>	DVGW W 363-(P) (01.06.2010) DIN EN 1074-1 (01.07.2000) DIN EN 1074-3 (01.07.2000) UBA BWGL-Metalle 3.1-Grundwerkst. (11.01.2023) UBA KTW-BWGL (07.03.2022) UBA ELASTOM (16.03.2016) DVGW W 270 (01.11.2007)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	19.10.2027 / 22-0717-WNV

70028-04-A-DE

25.01.2023 LE A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-05

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Typ 8015	Pressure rating: PN 10 Nominal diameter: DN 80	
Typ 8015	Pressure rating: PN 16 Nominal diameter: DN 100	
Typ 8015	Pressure rating: PN 16 Nominal diameter: DN 125	
Typ 8015	Pressure rating: PN 10 Nominal diameter: DN 150	
Typ 8015	Pressure rating: PN 16 Nominal diameter: DN 200	
Typ 8015	Pressure rating: PN 16 Nominal diameter: DN 250	
Typ 8015	Pressure rating: PN 16 Nominal diameter: DN 300	